5.0 ROOM REQUIREMENTS

MCESG Annex

Room Name: Conference Room 204

Space Characteristics

Function: Provides space for training and meeting to support a 24-hour operation.

Adjacencies: Near circulation and offices.

Area: 297 SF

Special Dimensions: Plan Dimension: 297 SF

Minimum ceiling height: 10 FT

Acoustics: Walls: STC 50 (walls between other adjacent rooms and spaces), Doors: STC 45. Floor/Ceiling assemblies shall have an

Impact Isolation Class (IIC) of 50 (IIC 45 if field tested).

Access: Accessed directly from corridor.

Number of Occupants: 24

Other Requirements: Provide cable TV, camera network, Tables and chairs for 24 occupants. Provide small closet for AV equipment

as indicated on concept drawings.

| Uniformat Section | Description | Qty | Size | Specific Requirements |
|----------------------|-------------------------------|-----------------|---------------|---|
| B2010 | Exterior Walls | | | Wall construction shall consist of load bearing CMU backup wall, brick veneer, cast stone trim and a wall cavity space containing the insulation, air, water and vapor barrier. |
| B202001 | Exterior Windows | As Indicated | As Required | ATFP compliant. Prefinished aluminum, thermal broken frames. Window shall be fixes operable double hung windows. Provide solid surface stools (sills). |
| B202004 | Exterior Glazing | | | Low-e, insulated, laminated glazing meeting ATFP requirements. Glazing shall be tinted matching base standards. Laminated glazing shall be a nominal 0.25" thick minimum. Insulating shall be argon filled. |
| C101001 | Fixed Partitions | | | Concrete Masonry Units (CMU) |
| C102001 | Interior Doors | As Indicated | 3X7 | Provide solid core flush wood door in a factory stained finish and hollow metal frames (field painted). |
| C102003 | Fire Doors | | | Where required. |
| C102007 | Interior Door Hardware | | | Provide the following but not limited to gasketing, protection plates, stops, cores and cylinders as required, lock trim. |
| C103003 | Marker Boards and Tack Boards | | 4'-0" x 8'-0" | Magnetic, Aluminum frame Marker board |
| C103004 | Identifying Devices | | | Wall mounted, architectural signage, include room number and name of function |

MCESG Annex

Room Name: Conference Room 204

| Uniformat Section | ne: Conference Ro | Qty | Size | Specific Requirements |
|----------------------|--|----------------|-----------|--|
| C103012 | Firestopping Penetrations | As required | | Penetration ratings shall match wall ratings. |
| C103015 | Specialties | As required | | Articulating mounts for TV's |
| C301002 | Acrylic Plaster Coating | | | High Performance (impact resistant) seamless 10 mil minimum interior acrylic coating system shall be used as an interior wall finish over CMU. |
| C302006 | Floor Finish | | | Minimal Maintenance, High-Durability, Resilient Flooring |
| C302007 | Wall Base Finish | | 4" H | Rubber |
| C303001 | Acoustical Tile and Grid | | 24" x 24" | Suspended Acoustical Ceiling Panels with a reveal edge and standard prefinished grid system. |
| C303002 | Gypsum Board Ceiling Finish | | | Provide gypsum board accent soffits and bulkheads. Provide level 4 finish on all exposed surfaces. |
| C304001 | Interior Coatings and Finishes | | | High Performance Latex Paint. Provide one or more painted accent walls. |
| D304001 | Air Distribution, Heating and Cooling | | | Provide ventilation complying with latest ASHRAE 62.1 requirements. Provide continuous ventilation equal to exhaust, ventilation air is to be fully conditioned and at neutral conditions of 70 degrees F and maximum 50% RH. |
| D304007 | Exhaust Systems | | | Provide continuous exhaust |
| D305003 | Fan Coil Units | | | Provide horizontal 4-pipe fan coil unit with secondary drain pan |
| D306001 | HVAC Controls | | | Provide DDC capable digital wall mounted thermostat. Thermostat will provide fan coil units with BACNET connectivity. |
| D4010 | Fire Alarm and Detection Systems | | | Provide audible notification appliance coverage in accordance with UFC 3-600-01 and UFC 4-021-01. |
| D4040 | Sprinkler Systems | | | Provide wet-pipe sprinkler coverage in accordance with UFC 3-600-01. |
| D502001 | Branch Circuit Wiring | | | Provide 120v duplex receptacles every 10'oc and as required to coordinate with D5030 equipment. Provide dedicated receptacle for AV equipment cabinet. Provide power to the conference room table via a floor box, recessed type, flush with floor. Provide receptacle for TV. Provide receptacle on dedicated circuit for the AV credenza. Provide ceiling mounted receptacle for projector. Provide power and switch for screen. |

MCESG Annex

Room Name: Conference Room 204

| Uniformat Section | Description | Qty | Size | Specific Requirements |
|----------------------|-------------------------------|-----|------|---|
| D502002 | Lighting Equipment | | | Target Illuminance = 50fc Fixture Type: recessed LED linear volumetric direct/indirect + downlight + wall wash Control: Vacancy Sensor + Switch at each door + Dimming. Provide scene control, minimum 4 programmed scenes. Provide at least 2 zones of lighting, above the table and along the walls. |
| D503001 | Telecommunications Systems | | | 1 – IPTV outlet wall mounted behind TV. Refer to D503001 for telecommunications floor box requirements. Provide data outlets in the following locations: Coordinate the rough-in location for voice and data communications outlets with the associated equipment mounting configuration 4 – Combination voice and NMCI data outlets 4 - OpenNet outlets adjacent to each voice/NMCI outlet. 1- SIPRNet outlet. Provide lock box for SIPRNet outlet Provide two combination voice and NMCI data outlets by A/V cabinet/credenza |
| D503004 | Television Systems | | | Provide three flush A/V floor boxes adjacent to the power and telecomm boxes below table Provide three 1-1/4" conduits below floor from equipment rack to the first A/V floor box below table. Interconnect each of these floor boxes with three 1-1/4" conduits. Provide a CATV outlet in the following locations: TV: 1 each, wall-mounted behind the equipment Projector: 1 each, mounted above the accessible ceiling AV Rack: 1 each Coordinate the rough-in location for CATV outlets with the associated equipment |
| D503005 | Security Systems | | | Provide pathway, camera drops and camera control cabling and hardware for MCESG official A/V Training/CATV. (PTZ cameras with integrated illumination assemblies). Each unit to be individually addressable and independently controlled. Route pathway, cabling/wiring to AV closet. Provide pathway, cabling/wiring to AV closet for MCESG official A/V Training. |

MCESG Annex

Room Name: Conference Room 204

| Uniformat Section | Description | Qty | Size | Specific Requirements |
|----------------------|---------------------|-----|------|---|
| E2020 | Movable Furnishings | | | 1 – Waste Receptacle 10 to 12 – Task Chair 1 – Large Conference table with power/data/comm 6 to 8 – Side Chairs 1- Credenza |